



RADE KONCAR CONTACTOR **CNN50**
50A/22kW (AC3, 400V/50Hz); 85A(AC1)

Contactor type		CNN 50		
Mechanical endurance	make/brake operations	x10 ⁶	5	
Insulation rating		V	1000	
Permissible ambient temperature		°C	from -25 to +55	
Consumption of electromagnet in cold state with Un				
AC operated	closing	VA	155	
	P.F.		0,6	
	closed	VA	12	
	P.F.		0,29	
DC operated	closing	W	90	
	closed	W	3,5	
Coil voltage tolerances			0.85-1.1Un	
Duration of making and breaking				
(values are also valid for voltages of electromagnet from 0.8 to 1.1 Un for each in cold and warm state).				
Total breaking time is addition of opening time and duration of electric arc.				
AC operated	closing time	ms	10 to 24	
	opening time	ms	7 to 10	
	duration of electric arc	ms	10 to 15	
DC operated	closing time	ms	15 to 40	
	opening time	ms	100 to 120	
	duration of electric arc	ms	10 to 15	
Frequency of switching operations				
without thermal relay				
utilization category	AC1	s/h	1000	
	AC2, AC3	s/h	750	
	AC4	s/h	250	
		s/h	15	
with thermal relay				
Resistivity to shocks (square shock)			9.25 and 5.4/10	
Short-circuit protection				
contactors without overload relays				
Main circuit				
With fuse links				
acc. To IEC 60947-4-1	Type of coord. "1" gl/gG	A	80	
	DIN VDE 0660 Part 102	Type of coord. "2"	A	40
Sizes of connection conductors				
for contact without thermal relay				
main circuit	Rigid solid	mm ²	1x6-50	
		stranded	mm ²	2x6-25
	multi-wire conductor with cable shoe	mm ²	1x6-35	
		standed with cable lug	mm ²	2x6-16
	flatbar	mm	-	
	protective conductor with cable lug	mm ²	-	
		Screw		M6
		Screw head		PZ2
		Tightening torque	Nm	3-4
	auxiliary circuit	single-wire conductor	mm ²	1-2.5
multi-wire conductor with cable shoe		mm ²	0.75-1.5	
Screw			M3.5	
Screw head			PZ2	
Tightening torque		Nm	0,8	

Loadability of auxiliary contacts

Rated continuous current I_{th} ; 35C		A	16
AC			
rated operational current $I_e/AC15$	230V	A	6
	400V	A	4
	500V	A	2,5
	690V	A	2,5
DC			
rated operational current $I_e/DC1$; L/R $\leq 1ms$	24V	A	10
	110V	A	3,2
	220V	A	0,9
	440V	A	0,33
	600V	A	0,22
rated operational current $I_e/DC13$	for 24V	A	10
	110V	A	1,8
	220V	A	0,9
	440V	A	0,27
	600V	A	0,18

Load carrying capacity of the main contacts

rated continuous current I_{th} ; 35C		A	85
AC1 utilization category			
rated current $I_e/AC1$		A	85
AC2 and AC3 utilization categories	for 230V	kW	15
(slip-ring and cage motors at 50Hz)	400V	kW	22
	690V	kW	33

AC4 utilization category

(electrical endurance of contacts:120.000)			
rated current	$I_e/AC4$	A	24
ratings of squirrel-cage motors at 50Hz for	230V	kW	6,9
	400V	kW	12
	500V	kW	15,8
	690V	kW	20,8

Load carrying capacity of contactors at

switching on and off of a.c. capacitors	I_e	A	
(electrical endurance amounts to 0.1 million switching operations)			
ratings of individual capacitors at 50 Hz for	230V	kvar	-
	400V	kvar	-
	500V	kvar	-
	690V	kvar	-
ratings of capacitor banks			
(minimum inductive reactance between two capacitors			
switched on in parallel amounts to $6\mu H$; 50 Hz	for 230V	kvar	-
	400V	kvar	-
	500V	kvar	-
	690V	kvar	-

Application in stator circuit of motor


intermittent operation AC2			
stator current at duty factor in intermittent periodic duty	20%	A	103
	40%	A	98
	60%	A	87
	80%	A	80

Application in rotor circuit of motor

intermittent operation			
rotor current at duty factor in intermittent periodic duty	10%	A	163
	20%	A	163
	40%	A	155
	60%	A	138
	80%	A	127
continuous operation		A	127
permissible voltage of motionless rotor			
	starting	V	1500
	regulation	V	750
	counter current breaking	V	660

Loadability by direct current

DC1 utilization category, non-inductive loads $LR \leq 1 ms$			
rated operational current I_e			
through one pole	for 24 V	A	70
	60 V	A	30
	110 V	A	6
	220 V	A	1,2
	440 V	A	0,48
	600 V	A	0,35
through three poles connected in series	for 24 V	A	70
	60 V	A	70



	110 V	A	70
	220 V	A	70
	440 V	A	3
	600 V	A	1
utilization categories DC3 to DC5 series and shunt motors ($L/R \leq 15$ ms)			
rated operational current I_e through one pole	for 24 V	A	5
	60 V	A	2
	110 V	A	0,75
	220 V	A	0,2
	440 V	A	0,1
	600 V	A	0,08
through three poles connected in series	for 24 V	A	70
	60 V	A	70
	110 V	A	70
	220 V	A	3,5
	440 V	A	0,6
	600 V	A	0,35

