

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Capacitor contactor

Name and address of the applicant

Rade Končar - Kontaktori i Relei D.O.O.  
III-ta Makedonska Brigada br.54  
1000 Skopje  
North Macedonia, Republic of

Name and address of the manufacturer

Rade Končar - Kontaktori i Relei D.O.O.  
III-ta Makedonska Brigada br.54  
1000 Skopje  
North Macedonia, Republic of

Name and address of the factory

Note: When more than one factory, please report on page 2

Rade Končar - Kontaktori i Relei D.O.O.  
III-ta Makedonska Brigada br.54  
1000 Skopje  
North Macedonia, Republic of

Ratings and principal characteristics

Ue (V) / Q (kvar)  
CNNK 10: 400/10; CNNK 12: 400/12,5;  
CNNK 15: 400/15; CNNK 25 and 25E: 400/25;  
CNNK 30: 400/30; CNNK 40: 400-440/40;  
CNNK 50: 400-440/50; CNNK 60: 400-440/60;  
For further ratings see Additional information.

Trademark / Brand (if any)

Rade Končar

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

CNNK 10; CNNK 12; CNNK 15; CNNK 25; CNNK 25E;  
CNNK 30; CNNK 40; CNNK 50; CNNK 60;

Additional information (if necessary may also be reported on page 2)

Ie@400V(A):  
CNNK 10: 14; CNNK 12: 18; CNNK 15: 22; CNNK 25 and 25E: 36;  
CNNK 30: 44; CNNK 40: 58; CNNK 50: 72; CNNK 60: 87;  
Uimp(kV): CNNK 10 to 30: 6; CNNK 40 to 60: 8  
Ui(V): CNNK 10 to 30: 690; CNNK 40 to 60: 1000;  
Utilization category for all types: AC-6b  
Auxiliary circuit: Ue(V): 400; Ith(A): 10; Ui(V): 690

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018  
IEC 60947-1:2007+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

HU23AMAU 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com

Date: 2024-02-13

Signature:



Tötös Tamás László