

IEC**IECEE**

®

TM

Ref. Certif. No.

HU-004007

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Rotary cam switches
Name and address of the applicant	Rade Koncar - Kontaktori i Relei DOO Skopje 3ta Makedonska Brigada No.54 1000 Skopje, North Macedonia
Name and address of the manufacturer	Rade Koncar - Kontaktori i Relei DOO Skopje 3ta Makedonska Brigada No.54 1000 Skopje, North Macedonia
Name and address of the factory	Rade Koncar - Kontaktori i Relei DOO Skopje 3ta Makedonska Brigada No.54 1000 Skopje, North Macedonia
Ratings and principal characteristics	Ue: 400V, Ui: 690V Ith (A):20, 25, 32, 40, 63 Ie (A):11, 16, 22, 30, 37 Utilization category: AC-3 Icw (A):250, 400, 600, 800, 800
Trademark (if any)	RK (see Test Report for logo)
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	BS 16, BS 25, BS 32, BS 40, BS 63 (See detailed in CB Test report)
Additional information (if necessary may also be reported on page 2)	---
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2020 IEC 60947-1:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	HU22VRV2 001

This CB Test Certificate is issued by the National Certification Body

**TÜVRheinland**®TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2022-09-09

Signature:

Ferencné Schmidt