

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Motor Contactor

Name and address of the applicant

Rade Koncar - Kontaktori i Relei DOO
3ta Makedonska Brigada no. 54,
1000 Skopje,
North Macedonia

Name and address of the manufacturer

Rade Koncar - Kontaktori i Relei DOO
3ta Makedonska Brigada no. 54,
1000 Skopje,
North Macedonia

Name and address of the factory

Note: When more than one factory, please report on page 2

Rade Koncar - Kontaktori i Relei DOO
3ta Makedonska Brigada no. 54,
1000 Skopje,
North Macedonia

Ratings and principal characteristics

1)Ue: AC 400V, 50Hz; Ie: 150A
2)Ue: AC 400V, 50Hz; Ie: 115A
Utilization category: AC-3

Trademark / Brand (if any)

RK (logo)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

1)CNN150; 2)CNN115

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

CN22JC1D 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2022-12-08

Signature:



G. Yin