

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC Contactor

Name and address of the applicant

RADE KONCAR KONTAKTORI I RELEI DOO
3ta Makedonska Brigada no. 54 1000 Skopje
North Macedonia, Republic of

Name and address of the manufacturer

RADE KONCAR KONTAKTORI I RELEI DOO
3ta Makedonska Brigada no. 54 1000 Skopje
North Macedonia, Republic of

Name and address of the factory

Note: When more than one factory, please report on page 2

RADE KONCAR KONTAKTORI I RELEI DOO
3ta Makedonska Brigada no. 54 1000 Skopje
North Macedonia, Republic of

Ratings and principal characteristics

Ui:690V; Uimp:6kV; AC-3; Ue:AC400V;
Ie:9A,12A; Ith=20A

Trademark / Brand (if any)

RADE KONCAR

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

CM1 9, CM1 12

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2023
IEC 60947-1:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

CN265TYZ 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2026-08-21

Signature:

Wencai Zhang